



Industrie Service

CERTIFICATE

(Certificate of conformity with technical requirements in:)
API STANDARD 6FA FIFTH EDITION, MAY 2020

Certificate No.: 302963

Ref. Test report No.: 302962

Name and postal address of manufacturer: **Zhejiang Yinke Valve Co., Ltd.**
Heyi Village, Oubei Street, Yongjia County,
Wenzhou City, Zhejiang Province, China

We hereby certify that the fire test on below valves have been conducted at the laboratory designated by manufacturer and witnessed by TÜV inspector according to requirements of API STANDARD 6FA FIFTH EDITION, MAY 2020 manufacturer's special requirements, the testing results of valves meet the requirements of API STANDARD 6FA FIFTH EDITION, MAY 2020

1. Description of Test Valve :

Type of Test Valve	NPS2 Class150 Ball Valve
Description of Valve	Ball Valve
Valve Size (NPS)	2"
Pressure Rating (Class)	Class 150
Valve Body Material	ASTM A105

2. Qualified Range of Valves :

Type	Ball Valves
Description of Valves	Ball Valves
Qualified Sizes (NPS) (according to API 6FA Table 4)	2", 2 ½", 3", 4"
Qualified Pressure Ratings (Class) (according to API 6FA Table 6)	150;300
Qualified Marking (according to API 6FA Para.4.5)	Qualified valves shall be permanently marked: 6FA
Remark: the technical data of test valve see back of this certificate appendix 1.	

This certificate is issued according to API STANDARD 6FA FIFTH EDITION, MAY 2020, based upon the result of testing report on above mentioned test valve. The additional valves qualification shall be limited on similar valves of same basic design as the test valve and same nonmetallic materials as the test valve in the seat-to-closure member seal, seat-to-body seal, stem seal, and body joint and seal according to API STANDARD 6FA FIFTH EDITION, MAY 2020, Para.5.

Shanghai, February 9, 2024
(Place, date)

Guilin Chen
TÜV SÜD Industrie Service GmbH
Westendstr.199
80686 München Germany





Industrie Service

CERTIFICATE

(Certificate of conformity with technical requirements in:)
API STANDARD 6FA FIFTH EDITION, MAY 2020

Certificate No.: 302967

Ref. Test report No.: 302966

Name and postal address of manufacturer: **Zhejiang Yinke Valve Co., Ltd.**
Heyi Village, Oubei Street, Yongjia County,
Wenzhou City, Zhejiang Province, China

We hereby certify that the fire test on below valves have been conducted at the laboratory designated by manufacturer and witnessed by TÜV inspector according to requirements of API STANDARD 6FA FIFTH EDITION, MAY 2020 manufacturer's special requirements, the testing results of valves meet the requirements of API STANDARD 6FA FIFTH EDITION, MAY 2020

1. Description of Test Valve :

Type of Test Valve	NPS4 Class150 Ball Valve
Description of Valve	Ball Valve
Valve Size (NPS)	4"
Pressure Rating (Class)	Class 150
Valve Body Material	ASTM A105

2. Qualified Range of Valves :

Type	Ball Valves
Description of Valves	Ball Valves
Qualified Sizes (NPS) (according to API 6FA Table 4)	4", 6", 8"
Qualified Pressure Ratings (Class) (according to API 6FA Table 6)	150;300
Qualified Marking (according to API 6FA Para.4.5)	Qualified valves shall be permanently marked: 6FA
Remark: the technical data of test valve see back of this certificate appendix 1.	

This certificate is issued according to API STANDARD 6FA FIFTH EDITION, MAY 2020, based upon the result of testing report on above mentioned test valve. The additional valves qualification shall be limited on similar valves of same basic design as the test valve and same nonmetallic materials as the test valve in the seat-to-closure member seal, seat-to-body seal, stem seal, and body joint and seal according to API STANDARD 6FA FIFTH EDITION, MAY 2020, Para.5.

Shanghai, February 9, 2024
(Place, date)

Guilin Chen
TÜV SÜD Industrie Service GmbH
Westendstr.199
80686 München Germany





Industrie Service

CERTIFICATE

(Certificate of conformity with technical requirements in:)
API STANDARD 6FA FIFTH EDITION, MAY 2020

Certificate No.: 303937

Ref. Test report No.: 303938

Name and postal address of manufacturer: **Zhejiang Yinke Valve Co., Ltd.**
Heyi Village, Oubei Street, Yongjia County,
Wenzhou City, Zhejiang Province, China

We hereby certify that the fire test on below valves have been conducted at the laboratory designated by manufacturer and witnessed by TÜV inspector according to requirements of API STANDARD 6FA FIFTH EDITION, MAY 2020 manufacturer's special requirements, the testing results of valves meet the requirements of API STANDARD 6FA FIFTH EDITION, MAY 2020

1. Description of Test Valve :

Type of Test Valve	NPS8 Class150 Ball Valve
Description of Valve	Ball Valve
Valve Size (NPS)	8"
Pressure Rating (Class)	Class 150
Valve Body Material	ASTM A105

2. Qualified Range of Valves :

Type	Ball Valves
Description of Valves	Ball Valves
Qualified Sizes (NPS) (according to API 6FA Table 4)	8" and larger
Qualified Pressure Ratings (Class) (according to API 6FA Table 6)	150;300
Qualified Marking (according to API 6FA Para.4.5)	Qualified valves shall be permanently marked: 6FA
Remark: the technical data of test valve see back of this certificate appendix 1.	

This certificate is issued according to API STANDARD 6FA FIFTH EDITION, MAY 2020, based upon the result of testing report on above mentioned test valve. The additional valves qualification shall be limited on similar valves of same basic design as the test valve and same nonmetallic materials as the test valve in the seat-to-closure member seal, seat-to-body seal, stem seal, and body joint and seal according to API STANDARD 6FA FIFTH EDITION, MAY 2020, Para.5.

Shanghai, February 13, 2024
(Place, date)



Guilin Chen
TÜV SÜD Industrie Service GmbH
Westendstr.199
80686 München Germany



Industrie Service

CERTIFICATE

(Certificate of conformity with technical requirements in:)
API STANDARD 6FA FIFTH EDITION, MAY 2020

Certificate No.: 303921

Ref. Test report No.: 303922

Name and postal address of manufacturer: **Zhejiang Yinke Valve Co., Ltd.**
Heyi Village, Oubei Street, Yongjia County,
Wenzhou City, Zhejiang Province, China

We hereby certify that the fire test on below valves have been conducted at the laboratory designated by manufacturer and witnessed by TÜV inspector according to requirements of API STANDARD 6FA FIFTH EDITION, MAY 2020 manufacturer's special requirements, the testing results of valves meet the requirements of API STANDARD 6FA FIFTH EDITION, MAY 2020

1. Description of Test Valve :

Type of Test Valve	NPS2 Class1500 Ball Valve
Description of Valve	Ball Valve
Valve Size (NPS)	2"
Pressure Rating (Class)	Class 1500
Valve Body Material	ASTM A105

2. Qualified Range of Valves :

Type	Ball Valves
Description of Valves	Ball Valves
Qualified Sizes (NPS) (according to API 6FA Table 4)	2", 2 ½", 3", 4"
Qualified Pressure Ratings (Class) (according to API 6FA Table 6)	1500;2500
Qualified Marking (according to API 6FA Para.4.5)	Qualified valves shall be permanently marked: 6FA
Remark: the technical data of test valve see back of this certificate appendix 1.	

This certificate is issued according to API STANDARD 6FA FIFTH EDITION, MAY 2020, based upon the result of testing report on above mentioned test valve. The additional valves qualification shall be limited on similar valves of same basic design as the test valve and same nonmetallic materials as the test valve in the seat-to-closure member seal, seat-to-body seal, stem seal, and body joint and seal according to API STANDARD 6FA FIFTH EDITION, MAY 2020, Para.5.

Shanghai, February 13, 2024
(Place, date)


Guilin Chen
TÜV SÜD Industrie Service GmbH
Westendstr.199
80686 München Germany





Industrie Service

CERTIFICATE

(Certificate of conformity with technical requirements in:)
API STANDARD 6FA FIFTH EDITION, MAY 2020

Certificate No.: 303929

Ref. Test report No.: 303930

Name and postal address of manufacturer: **Zhejiang Yinke Valve Co., Ltd.**
Heyi Village, Oubei Street, Yongjia County,
Wenzhou City, Zhejiang Province, China

We hereby certify that the fire test on below valves have been conducted at the laboratory designated by manufacturer and witnessed by TÜV inspector according to requirements of API STANDARD 6FA FIFTH EDITION, MAY 2020 manufacturer's special requirements, the testing results of valves meet the requirements of API STANDARD 6FA FIFTH EDITION, MAY 2020

1. Description of Test Valve :

Type of Test Valve	NPS4 Class1500 Ball Valve
Description of Valve	Ball Valve
Valve Size (NPS)	4"
Pressure Rating (Class)	Class 1500
Valve Body Material	ASTM A105

2. Qualified Range of Valves :

Type	Ball Valves
Description of Valves	Ball Valves
Qualified Sizes (NPS) (according to API 6FA Table 4)	4", 6", 8"
Qualified Pressure Ratings (Class) (according to API 6FA Table 6)	1500;2500
Qualified Marking (according to API 6FA Para.4.5)	Qualified valves shall be permanently marked: 6FA
Remark: the technical data of test valve see back of this certificate appendix 1.	

This certificate is issued according to API STANDARD 6FA FIFTH EDITION, MAY 2020, based upon the result of testing report on above mentioned test valve. The additional valves qualification shall be limited on similar valves of same basic design as the test valve and same nonmetallic materials as the test valve in the seat-to-closure member seal, seat-to-body seal, stem seal, and body joint and seal according to API STANDARD 6FA FIFTH EDITION, MAY 2020, Para.5.

Shanghai, February 13, 2024
(Place, date)


Guilin Chen
TÜV SÜD Industrie Service GmbH
Westendstr.199
80686 München Germany





Industrie Service

CERTIFICATE

(Certificate of conformity with technical requirements in:)
API STANDARD 6FA FIFTH EDITION, MAY 2020

Certificate No.: 303933

Ref. Test report No.: 303934

Name and postal address of manufacturer: **Zhejiang Yinke Valve Co., Ltd.**
Heyi Village, Oubei Street, Yongjia County,
Wenzhou City, Zhejiang Province, China

We hereby certify that the fire test on below valves have been conducted at the laboratory designated by manufacturer and witnessed by TÜV inspector according to requirements of API STANDARD 6FA FIFTH EDITION, MAY 2020 manufacturer's special requirements, the testing results of valves meet the requirements of API STANDARD 6FA FIFTH EDITION, MAY 2020

1. Description of Test Valve :

Type of Test Valve	NPS8 Class1500 Ball Valve
Description of Valve	Ball Valve
Valve Size (NPS)	8"
Pressure Rating (Class)	Class 1500
Valve Body Material	ASTM A105

2. Qualified Range of Valves :

Type	Ball Valves
Description of Valves	Ball Valves
Qualified Sizes (NPS) (according to API 6FA Table 4)	8" and larger
Qualified Pressure Ratings (Class) (according to API 6FA Table 6)	1500;2500
Qualified Marking (according to API 6FA Para.4.5)	Qualified valves shall be permanently marked: 6FA
Remark: the technical data of test valve see back of this certificate appendix 1.	

This certificate is issued according to API STANDARD 6FA FIFTH EDITION, MAY 2020, based upon the result of testing report on above mentioned test valve. The additional valves qualification shall be limited on similar valves of same basic design as the test valve and same nonmetallic materials as the test valve in the seat-to-closure member seal, seat-to-body seal, stem seal, and body joint and seal according to API STANDARD 6FA FIFTH EDITION, MAY 2020, Para.5.

Shanghai, February 13, 2024
(Place, date)



Guilin Chen
TÜV SÜD Industrie Service GmbH
Westendstr.199
80686 München Germany